



CITY OF SAVANNAH

HISTORIC PRESERVATION COMMISSION

REQUEST FOR CERTIFICATE OF APPROPRIATENESS

Petitioner: JCB Roofing, Allie Morgan

MPC File No.: 26-002112-COA

Address: 309 West Henry Street

PIN: 20052 29003

Zoning: TN-1

Staff Reviewer: Alexander Merced

Date: May 27, 2026

NATURE OF REQUEST:

The applicant would like to replace the deteriorated metal roof in-kind.

CONTEXT/SURROUNDING AREA:

The building was constructed in 1873 and is a contributing resource within the National Register Victorian Historic District and the local Victorian Historic District.

FINDINGS:

The following standards from the Sec 7.9 - Victorian Historic District Ordinance apply:

Secretary of the Interior's Standards and Guidelines for Rehabilitation. Material changes to contributing resources and resources that are eligible for listing as contributing shall be evaluated by use of the current edition of the Secretary of the Interior's Standards and Guidelines for Rehabilitation as published by the U.S. Department of the Interior. In considering proposals for alterations to contributing resources, the documented original design of the resource may be considered.

Secretary of the Interior's Standards 2– Historic Character. The historic character of a property shall be retained and preserved. The removal of historic materials or alteration of features and spaces that characterize a property shall be avoided.

The historic character of the property will remain unchanged. The standard is met.

Visual Compatibility Criteria. To maintain the special character of the Victorian Historic District as identified in the architectural survey and visual analysis, new construction and any material change in appearance shall be consistent with the standards, criteria and guidelines developed for the district. The applicable criteria below shall be used to assess new construction and material changes. These criteria shall not be the basis for appeal to

any board, commission or administrator described in this Ordinance, or to the Mayor and Aldermen.

Materials. *The relationship of materials and textures of the proposed building or structure shall be visually compatible with the contributing buildings and structures to which it is visually related.*

The metal roof will be replaced in-kind. The standard is met.

Victorian Historic District Design Standards.

New Construction, Additions, and Alterations. The intent of these standards is to ensure appropriate new construction, additions, and alterations within the Victorian Historic District. They are also intended to protect the historic integrity of contributing resources. Designs for new construction are to be consistent with contributing resources from the district's Period of Significance (1870-1923).

The following design standards shall apply to new construction, additions, alterations to contributing and non-contributing resources, and site alterations, unless otherwise specified. Though certain building materials are prescribed below, the Historic Preservation Commission may approve alternative materials that are not listed as prohibited upon a showing by the applicant that the material or product is visually compatible with historic building materials and has performed satisfactorily in the local climate.

Roof, Contributing Resources.

Roof, Materials, Contributing Resources.

Original roof material shall be repaired rather than replaced, provided however, if the degree of degradation does not allow repair, the degradation shall be photographically documented and verified by the Planning Director, and the new roof shall be of the same material and configuration as the original (except wood or asbestos).

Metal roofs shall have a metal drip edge covering all edges.

The above standards are met.

STAFF RECOMMENDATION:

Approve the roof replacement at 309 West Henry Street as requested because it is visually compatible and meets the standards.

MW: CC: APM

Note: This recommendation could change subject to new information provided at the Historic Preservation Commission meetings. Final decisions will be made by the Historic Preservation Commission at the public hearing based on information provided at the meeting, as well as information submitted for the staff recommendation.