



Savannah Historic District Board of Review

April 12, 2023 Historic District Board of Review

Title

Petition of Felder & Associates | 23-0000197-COA | 27 Barnard Street | Alterations and Additions

Description

The applicant is requesting approval for alterations to the property located at 27 Barnard Street.

Recommendation

Approve alterations to the property located at 27 Barnard Street **with the following conditions** because the proposed work is otherwise visually compatible and meets the standards:

- 1. All signage must return to the Board for a COA.**
- 2. All awnings must have a minimum vertical clearance of eight (8) feet above the sidewalk.**

Contact

Financial Impact

Review Comments

Attachments

- 📎 [Staff Report - 23-000197-COA 27 Barnard St.pdf](#)
- 📎 [Submittal Packet - 27 Barnard St.pdf](#)
- 📎 [Previous Submittal Packet.pdf](#)
- 📎 [1955 and 1973 Sanborn Map.pdf](#)
- 📎 [1970s COA and photos.pdf](#)
- 📎 [1980s photos.pdf](#)