

# Savannah Historic District Board of Review

# March 8, 2023 Historic District Board of Review

#### **Title**

Petition of David Bloomquist | 23-000588-COA | 21 West York Street | Rehabilitation and Alterations

## **Description**

The applicant is requesting brick repointing, brick repair, in-kind brick replacement in areas with disintegrated brick, stabilization of a brick wall, and the installation of two security lights on the west wall of 21 West York Street.

#### Recommendation

<u>Approval</u> to repoint mortar, repair cracked brick, replace damaged brick with in-kind materials, stabilize the wall, and install security lights for the historic resource located at 21 West York Street <u>with the following conditions</u>, to be submitted to staff for final review and approval because the work is otherwise visually compatible and meets the standards.

- 1. Provide information regarding which of the five above mentioned mortar types will be used.
- 2. Provide a mortar sample to staff prior to start of 4-foot-by-4-foot test patch area and upon approval, schedule a time with staff to observe the 4-foot-by-4-foot test patch area.
- 3. Install steel straps and light fixtures through the mortar joints rather than the historic brick.

### Contact

**Financial Impact** 

**Review Comments** 

# **Attachments**

- Submittal Packet 21 W. York St..pdf
- Staff Research 21 W. York St..pdf
- Staff Report -23-000588-COA 21 W York St.pdf